

CONTENTS

SECTION	Page
Contents	i
Certification	ii
PART I - GENERAL INFORMATION	1
A. GENERAL	1
1. Name and Type	1
2. Date of Initial Operation	1
3. Location	1
4. Name and Address of Owner	1
5. Facility Contacts	1
B. SITE DESCRIPTION AND OPERATIONS	1
1. Facility Location, Layout and Operations	1
2. Fuel Ullage	2
3. Piping.....	2
4. Spill Risk	3
5. Location of Chemicals.....	3
6. Permits Required.....	3
PART II - OPERATIONAL PROCEDURES FOR SPILL PREVENTION.....	4
A. TANK REFUELING OPERATIONS	4
PART III - SPILL COUNTERMEASURES AND REPORTING	5
A. SPILL AND COUNTERMEASURES	5
B. SPILL REPORTING	6
C. TRAINING	7
D. PERSONAL PROTECTIVE EQUIPMENT (PPE).....	7
 <u>APPENDIX</u>	
A. TANK ULLAGE/FUELING LOG AND FUEL UNLOADING PROCEDURE CHECKLIST	
B. TANK INSPECTION CHECKLIST	
C. SPILL REPORTING FORM	
D. TRAINING OUTLINE AND RECORD FORM	
E. DIESEL FUEL “MATERIALS SAFETY DATA SHEET”	
F. SPILL CLEANUP KIT INFORMATION	
G. FUEL TANK DATA AND INFORMATION SHEET	
H. PERMITS	
I. PHOTOGRAPHS OF FACILITY, TANK AND PIPING	
J. FIGURE 1, FIGURE 2 and FIGURE 3 (MAPS & DRAWINGS)	

**SPILL PREVENTION, CONTROL, AND COUNTERMEASURES
BEST MANAGEMENT PLAN**

N O A A

**NATIONAL WEATHER SERVICE
Elko Weather Forecast Office
3720 Paradise Drive
Elko, Nevada**

Designated Person Responsible for Spill Prevention (DRO):

Printed Name: Kevin Baker - MIC

Signature: _____

Date: _____

Phone: 775-778-6716

The Regional Environmental Compliance Officer (RECO) has reviewed the facility and determined that an SPCC Plan is not required per 40 CFR 112. This Plan is developed strictly as a Best Management Plan. The determination is based on :

 X The facility does not exceed capacity.

 The facility meets capacity requirements but, a discharge will not reach navigable waterways.

RECO Printed Name: Thanh Minh Trinh, P. E.
Phone: (206) 526-6647

RECO Signature: _____

Date: _____

PART I - GENERAL INFORMATION

A. GENERAL

This section of the Best Management Practices plan provides general information about the facility.

- 1. Name:**
National Weather Service , Weather Forecast Office (WFO)
- 2. Date of Initial Operation:** August 1995 — Aboveground Fuel Tank
- 3. Location**

National Weather Service Office (WFO)
Street: 3720 Paradise Drive
City: Elko
State/Zip: Nevada 89801
Latitude: 40° - 51' - 36" North
Longitude: 115 ° - 44' - 33" West
Elevation: 5224 ft. MSL
- 4. Name and phone number of Owner (POC)**

National Weather Service
Western Region
125 South State Street, Room 1311
Salt Lake City, Utah 84138-1102
Phone: (801) 524-5138 Ext 223
- 5. Facility Contacts (Environmental coordinator, Area Safety Representative, Alternate, Focal Point, First Responder)**

<u>Name</u>	<u>Title</u>	<u>Telephone Number</u>
James R. Moore	Envir. Coord.	(775) 778-6716
Kevin Baker	MIC	(775) 778-6716

B. SITE DESCRIPTION AND OPERATIONS

This section describes the site and its operations.

1. The facility is located within the Elko City limits. The site consists of a 10-acre plot of ground containing the National Weather Service (NWS) Weather Forecast Office (WFO) building, a garage, a balloon inflation building, an engine-generator building, a paved parking area and miscellaneous meteorological instruments and landscaping. The site is located on high ground with the general slope of the site towards the east (Appendix J -Figure 1 - Site Location Map). The facility is located in a developing area of the city but with the nearest buildings being approximately 1/4-mile away. A 1,000-gallon aboveground storage tank (AST) supplies diesel fuel to an emergency generator through a small 27-gallon day tank which is attached to the generator. The AST is located in a non-fenced area behind the generator building. Both the generator building and the AST are located away from the parking lot and neither are attached to the NWSO (Figure 2). About 50% of the 10-acre site is undeveloped with open ground and sage brush surrounding the developed parts of the site.

The AST is a 1,000-gallon, Convault, rectangular shaped tank and is installed on a concrete pad. The primary steel tank is encased in a 6-inch thick reinforced concrete secondary containment vault. The AST has primary and emergency vents, as well as overfill protection that includes an automatic shutoff valve, an overfill alarm and a 7-gallon overfill bucket. The AST is also provided with an electronic monitoring and alarm system that monitors the interstitial area inside the tank for leakage. The system also monitors for overfill conditions. Should either an overfill or leakage in the interstitial area occur, the system provides both visual and audible alarms.

2. The AST is normally “topped off” once each year with the normal amount of fuel being added of about 600-gallons. The generator is run once each week for an hour for maintenance and testing purposes. Fuel consumption will change based on the frequency and duration of any power outages.
3. A 3/4-inch supply line from the AST is encased in a 4-inch diameter polyvinyl chloride pipe that exits the AST from it’s top and runs to the exterior wall of the generator building. There is a 27-gallon day tank located between the AST and the generator. The day-tank sits in a “spill pan” at the base of the generator and has a high-level alarm switch which activates a visual and an audible alarm in the office when spilled fuel rises in the “spill pan”.
4. The AST and associated generator are located on high ground with the general slope of the land towards the east. It is approximately 1/2-mile to the point where drainage from this site will intersect with drainage from other areas. Any spilled fuel oil from the AST or the tank truck would be absorbed by the soil near the tank area. The Humboldt River is located approximately 1-1/2-miles south of the site. Elko is located in a desert area with little rainfall. In the event of diesel fuel spillage, all fuel should remain within the boundaries of the NWS properties and any soil contamination can be mitigated by excavation and aeration of the contaminated soil, if required. There are no storm drain inlets near the AST or generator room.

5. In addition to the diesel fuel used for the emergency power generator, this facility also stores chemicals (e.g., oils, paint, solvents, antifreeze, cleaning compounds and pesticides) for the operation, maintenance and testing of station facilities and equipment. These are stored/used in the following location(s):

Location : (Example: Flammable locker next to the coffee mess)

- a. Unused oil in original containers — Stored in Generator Building
- b. Paint in spray cans — Stored in Flammable Locker located in storage room
- c. Station Cleaning Supplies — Stored in the janitor's closet and storage room
- d. Lubricants in spray cans — Stored in Flammable Locker located in the Storage room
- e. Pesticides — Stored in plastic container on shelf in station storage room
- f. New Batteries — Stored in the station storage room in original containers
- g. New Fluorescent Light tubes — Stored in original containers in the station storage room.

6. Permits Required (Copies Attached in Appendix H)

- a. State of Nevada "Hazardous Materials Storage Permit" — Permit was issued by the Nevada State Fire Marshall. Permit # 2357-5574. Annual renewal required. No annual renewal fees required. Permits are sent to Western Region.

Part II - OPERATIONAL PROCEDURES FOR SPILL PREVENTION

A. Tank Refueling Operations. This section discusses the procedures that shall be used during unloading of fuel from the tank truck into the AST to prevent spills. This procedure shall be documented every time refueling occurs using the form found in Appendix A. Copies of this form shall be kept for five (5) years.

1. The following procedure shall be used **before** fuel unloading: (APPENDIX A)

- a. The Facility Manager or his designated representative should determine the available capacity (ullage) of the AST by converting the reading on the fuel gauge to gallons (See Appendix A). This ullage is communicated to the fuel supply contractor and marked in the fueling log.
- b. Move spill containment equipment such as booms, spill barriers or spill kits into the unloading area.
- c. Block the tank truck wheels.
- d. Place drip pans under all pump hose fittings (if applicable) before unloading.
- e. The Facility Manager or his designated representative and the delivery driver ensure the fill nozzle is placed in the appropriate AST appurtenance.

2. The following procedure shall be used **during** the fuel unloading period: (APPENDIX A)

- a.. The Facility Manager or his designated representative and the delivery driver shall remain with or near the vehicle and the fuel tanks at all times during unloading. Gauges on the AST and the truck, as well as the fueling nozzle, shall be continuously monitored to ensure the ullage is not exceeded. If the audible high-level alarm sounds, stop the unloading procedure immediately.

3. The following procedure shall be used **after** fuel unloading is completed: (APPENDIX A)

- a. Record the amount of fuel transferred to the AST in the log (Appendix A).
- b. Drain the fill hose and then ensure that all drain valves are closed (if applicable) before removal of the hose from the tank
- c. Pour any uncontaminated fuel in the drip pans, tank truck containment pool, or spill pipe spill bucket container into the AST (if it has the capacity) or dispose of appropriately.
- d. Inspect the tank truck before removing the blocks to ensure the lines have been disconnected from the tank.
- e. Remove the blocks from truck wheels.
- f. Place a copy of the fuel-unloading checklist in the SPCC BMP.

PART III - SPILL COUNTERMEASURES AND REPORTING

A. SPILL COUNTERMEASURES

This section presents countermeasures to contain, clean up, and mitigate the effects of any oil spills at this site.

A spill containment and cleanup activity will never take precedence over the safety of personnel. No countermeasures will be undertaken until conditions are safe for workers. The **SWIMS** procedure should be implemented as countermeasures:

- S -** Stop the leak and eliminate ignition sources.
 - a. Attempt to seal or some how stop leak if it can be done safely.
 - b. Attempt to divert flow away from any drainage ditch, storm sewer or sanitary sewer with a spill barrier or the contents of spill kit. The spill kit is located in the Generator Building.
 - c. Eliminate all ignition sources in the immediate area.

- W -** Warn others.
 - a. Yell out “SPILL”. Inform the person in-charge at your facility.
 - b. Account for all personnel and ensure their safety.
 - c. Notify contacts and emergency response contractor as described in the following section for assistance in control and cleanup.

- I -** Isolate the area.
 - a. Rope off the area

- M -** Minimize your exposure to the spilled material by use of appropriate clothing and protective equipment. If possible, remain upwind of the spilled material.

- S -** Standby to assist the emergency response contractor.

B. SPILL REPORTING (APPENDIX C):

1. General Notification Procedures For All Spills:

Within 24 hours, the responsible person or designee (on this plan title page or in Part 1, A.5.) is directly charged with reporting **all** oil spills that result from facility operations as follows:

- a. In the event of an emergency (e.g., fire, or injury), call **911**.
- b. Notify the appropriate persons within your WFO, Regional Office and line office:

National Weather Service:

Mike Jacob, NWS Environmental Compliance Officer (NWSH)

Phone number: (301) 713-1838 Ext. 165, Jmichael.Jacob@NOAA.GOV

Olga Kebis, NWS Safety Officer (NWSH)

Phone number: (301) 713-1838 Ext. 173, Olga.Kebis@NOAA.GOV

**Robert Kinsinger, Regional Environmental Compliance Coordinator (ECC)
in Western Region Headquarters**

Phone number: (801) 524-5138 Ext. 223 Email: robert.kinsinger@noaa.gov

- c. **NOAA Environmental Compliance and Safety Office Program:** E-mail or call your RECO.

WASC Thanh.M.Trinh@NOAA.GOV Phone: (206) 526-6647

- d. **LECO – Elko Emergency Plan Commission (775) 738-3211**

Note: LECO & RECO must determine if Federal or State notification is required and follow up accordingly. (The State of Nevada requires notification when a release of petroleum products exceeds 25-gallons or if there is a potential contamination of 3 cubic yards of soil.
Call DCNR at (800) 922-0900 Ext 4670 or (775) 687-4670

2. Cleanup Contractor Notification

An emergency response contractor should also be notified to assist with the clean up if necessary. **NWS/WFO Elko** has identified and contacted the following contractors that are available for an emergency response:

<u>Contractor(s)</u>	<u>Phone Number</u>
• Safety-Kleen	(775) 331-9400
• Environmental Reclamation Inc. (ERI)	(775) 753-8125
• Reno Drain Oil Service	(775) 342-0351

3. Spill Report

Complete a spill report using the format provided in APPENDIX C. Send this to your RECO with a copy to the Western Region ECC.

C. Training

The Environmental/Safety Focal Point and an alternate should be trained in 1)the refueling procedures, 2)countermeasures, and 3)spill reporting. The alternate should be designated in case the primary person is off site at the time of a spill.

(See APPENDIX D for Training Outline and Training Record form)

D. Personal Protective Equipment (PPE)

- PPE information is specified in the **MSDS**
- Eye protection is accomplished by the use of **Chemical Goggles**
- Hand protection is accomplished by the use of **Nitril Gloves**
- Other clothing & equipment - if contaminated, must be removed and laundered before reuse. Items which cannot be laundered should be discarded.
- Appropriate NIOSH-approved respiratory protection to avoid inhalation of mist or vapors which may be present under hot temperature conditions.

APPENDIX A

TANK ULLAGE/FUELING LOG AND FUEL UNLOADING PROCEDURES CHECKLIST

APPENDIX A-1
TANK ULLAGE AND FUELING LOG

Station Name: _____

Tank Capacity: _____ gallons

Date	Initials	Gauge Reading	Initial Volume of Fuel in Tank ^a (Gallons)	Available Capacity or Ullage ^b (Gallons)	Quantity Added (Gallons)	Comments

Notes:

- a. From gage reading
- b. Available capacity = tank capacity - initial volume of fuel in tank

APPENDIX A-2

FUEL UNLOADING PROCEDURE CHECKLIST

Date: _____ **Tank:** _____

NWS Representative: _____ **Supplier:** _____

ITEM	DESCRIPTION	COMMENTS
✓		
The following six items must be completed <u>prior</u> to fuel unloading:		
1	Move spill containment equipment, such as booms or spill barriers, into the unloading area.	
2	Ensure the audible high-level alarm system and automatic shutoff valve are functioning properly (if applicable).	
3	Determine the available capacity (ullage) of the tank by converting the reading on the fuel gauge to gallons (see Appendix A-1). The ullage should then be marked in the fueling log and communicated to the tank truck unloading contractor.	
4	Block the wheels of the tank truck.	
5	Place drip pans under all pump hose fittings (if applicable) after the hose is hooked up to the tank and before unloading.	
6	Ensure the fill nozzle is placed in the appropriate tank appurtenance.	
During unloading		
7	Ensure that the NWS representative and the tank truck operator remain with the vehicle at all times during unloading.	
8	Monitor the gauges on the tank and the truck continuously to ensure the ullage is not exceeded.	
After fuel unloading is completed		
9	Record the amount of fuel unloaded in the log (Appendix A-1).	
10	Before removing the fill hose from the tank, ensure that it is drained and that all drain valves are closed (if applicable).	
11	Any fuel accumulated in the drip pans or spill container on the fill pipe should be poured into the tank (if it has the capacity) or disposed of appropriately (describe how it was disposed of, if applicable).	
12	Inspect the tank truck before removing the blocks to ensure the lines have been disconnected from the tank.	
13	Remove the blocks from the tank truck wheels.	
14	Place a copy of this fuel unloading procedure checklist in the Best Management Plan.	

APPENDIX B

TANK INSPECTION CHECKLIST

MONTHLY INSPECTION CHECKLIST			
Date of Inspection:		Tank Name or No.:	
Date of Last Inspection:		Inspected by:	Signature:
A. TANKS		YES	NO
1. Are tanks marked properly?			
2. Is area atop and around tank and within berm free of combustible materials and debris? stains?			
3. Is there any oil on the ground, concrete, or asphalt around the tank?			
4. Are there any visible cracks or indications of corrosion on the tank, at fittings, joints, or seals (such as paint peeling or rust spots)?			
5. Are there any raised spots, dents, or cracks on the tank?			
6. Does it appear that the foundation has shifted or settled?			
7. Is the fuel gauge working properly?			
8. Are all vents clear so they may properly operate?			
9. If rainwater is present within containment, does capacity remain for spill control, if applicable?			
B. PIPING			
1. Is there any oil on the outside of or under any aboveground piping, hoses, fittings, or valves?			
2. Are aboveground piping hoses, fittings, or valves in good working condition?			
C. SECURITY/SAFETY/SPILL COUNTERMEASURES			
1. Are lights working properly to detect a spill at night?			
2. Are all locks in the "lock" position?			
3. Are all warning signs properly posted and readable?			
4. Are vehicle guard posts in place and properly secured (if applicable)?			
5. Are spill kits easily accessible, protected from the weather, complete, and replenished if necessary?			
Corrective Actions Required:			

ANNUAL INSPECTION CHECKLIST (Page 1 of 1)			
Date of Inspection:		Tank Name or No.:	
Date of Last Inspection:		Inspected by:	
		Signature:	
A. MONTHLY CHECKLIST	YES	NO	NOTES
1. Have monthly inspection checklists been completed?			
B. TANKS			
1. Are all alarms and automatic shutoff devices working properly?			
2. Is interstitial monitor functioning properly (if applicable)?			
C. OTHER			
1.			
Corrective Actions Required:			

APPENDIX C

SPILL REPORTING

APPENDIX C
SPILL REPORTING

1. GENERAL		
Name of Facility:	Address:	
Completed By:	Organization:	
Position:	Phone:	
2. SPILL INFORMATION		
Date:	Time:	
Location at Facility:	Quantity:	
Substance Spilled:	Other:	
3. OUTSIDE NOTIFICATIONS: (Insert telephone numbers)		
Agencies	Record the external regulatory agency representative name when making the calls.	Date & Time
Call 911 for emergency assistance		
Regional Management (see Part III Section B subparagraph 1.b) (801) 524-5138 Ext.223		
Line Office Environmental Compliance Officer (see Part III Section B subparagraph 1b) (301) 713-1838 Ext 165 or Ext 173		
NOAA, RECO (see Part III Section B subparagraph 1.c) (205) 526-6647		
EPA National Response Center or U.S. Coast Guard : (800) 424-8802		
State of Nevada Department of Environmental Protection. (775) 687-4670		
LECO — Elko Emergency Plan Commission (775) 738-3211		
4. INFORMATION ON SOURCE AND CAUSE		
5. DESCRIPTION OF ENVIRONMENTAL DAMAGE		
6. CLEANUP ACTION(S) TAKEN		
7. CORRECTIVE ACTION(S) TO PREVENT FUTURE SPILLS		

Note: All information must be filled in. If something is unknown, write “unknown”.
Copies must be sent, preferably by e-mail, to the NWS/NOAA personnel listed above.

APPENDIX D

TRAINING OUTLINE & TRAINING RECORD

APPENDIX D-1

TRAINING OUTLINE: SPILL PREVENTION, CONTROL AND COUNTERMEASURES

Training will be provided for facility personnel at the following times:

1. System startup or whenever new equipment is installed
2. Within the first week of employment for new personnel
3. Annually

The training will include complete instruction in the elements of the facility's Spill Prevention, Control, and Countermeasure plan and will include the following:

1. Pollution control laws, rules, and regulations including a summary of Title 40 of the Code of Federal Regulations Part 112 "Oil Pollution Prevention" (see Attachment)
2. Fuel Storage System
 - A. Purpose and application of the following system elements:
 1. Tanks
 2. Piping
 3. Pumps
 4. Accessory equipment
 5. Electronic monitors
 - B. Operation, maintenance, and inspection of system elements
3. Spill Prevention
 - A. Potential spill sources
 - B. Spill flow direction and impact on navigable waters
 - C. Procedures to prevent spills, especially during fuel unloading
4. Spill Control
 - A. Secondary containment
 - B. Safety valves
 - C. Pump and equipment shutoff switches
 - D. Use of catch basin inlet covers or other diversionary devices
5. Spill Countermeasures
 - A. Location and use of emergency phone numbers
 - B. Location and use of fire extinguishers
 - C. Location and use of spill cleanup kit
 - D. Stopping the leak

APPENDIX D-2

TRAINING REPORT FORM

DATE OF TRAINING	EMPLOYEE TRAINED	TRAINER	REMARKS

APPENDIX E

MATERIALS SAFETY DATA SHEET ATTACHMENT

APPENDIX F

SPILL CLEANUP KIT INFORMATION ATTACHMENT

APPENDIX G

FUEL TANK DATA AND INFORMATION

APPENDIX H

PERMITS

APPENDIX I

PHOTOGRAPHS OF FACILITY TANKS AND PIPING

APPENDIX J (MAPS & DRAWINGS)

FIGURE 1:Site Location Map

FIGURE 2:Topographic Map & Site Layout

FIGURE 3: Site Piping Diagram